6

Scott. II-27—40,004—6-11-28.

Law (Edn) (19 29) Department.

dlg SERIES.

G.O. No. 1191

DATED 10-6-29

St. Agnes High School, Mangalore - Included in the list of approved works -

C.F. 30.

Educational **DEPARTMENT.** LE1477B 30.5.29.

Received ..... 192 *Registered* 192

Subject.

St.Agnes High School, Mangalore - building scheme



ENCLOSURES.
No .....
.....
Spare copies.....

R.C. No. 459 EDN

Station Madras *Dated the* 25th May 1929

From (Name) R.G.Grieve Esq., M.A.,

(Designation) Ag:Director of Public Instruction

To The Secretary to the Government of Madras,

Law (Education) Department.

Sir,

I have the honour to submit herewith plans and estimates towards the construction of an additional block of buildings for the St.Agnes High School, Mangalore.

The plans and estimates have been scrunitised by the Consulting Architect and as a result of the scrutiny he has reduced the estimate from Rs.40890 to Rs.32800 vide his remarks - copies enclosed - The Correspondent has accepted the Consulting Architect's revised estimate and has also agreed to adopt his suggestions.

The school is in need of additional accommodation as the classes are now held very close together. I, therefore recommend that the scheme be approved by Government at an

estimated cost of Rs.32800 (Thirty two thousand eight hundred) and that sanction be accorded to its inclusion in the list of approved works, so as to render the school eligible for a grant of Rs.16400 if and when funds become available, provided that the conditions of the Grant-in-Aid Code are duly complied with

I have the honour to be,
Sir,
Your most obedient servant,

For Director of Public Instruction

T R 27/5

27/5

Copy of Deputy Consulting Architect's notes, dated 5-4-1929.

- --

Saint Agne's Girls' High School, Mangalore

The width of walls in foundations and basement as now proposed by the Correspondent vide sketch below may be approved.

(2) Terrace flooring with Hourdis Tiles and paving with 9" x 9" Mission tiles over 3" of concrete in lime mortar may also be approved. But the following sections of joists require alteration.

Sections required		Estimate for
Joists in rear rooms	2½" x 5" partly fixed	2½" x 8"
Joists in corner rooms	- do - - do -	2½" x 8"
Joists in class rooms and Hall	2½" x 7" -do-	2½" x 8"
Joists in parlour	2½" x 5" - do -	2½" x 8"
Joists in Portico	2½" x 6" --do -	2½" x 8"
Joists in verandah	2½" x 5" - do -	2½" x 8"

all members are treated as partly fixed.

(3) There is a considerable difference in cost between ceiling the underside of the tiled roof with cedar wood planks, (not to speak of Teak) as compared with ceiling tiles, and it is considered that Mission tile ceiling is good enough for its purpose. The Correspondent's request to substitute cedar wood plank may be disallowed as extravagent.

(4) The rate of roofing with I class Mangalore Mission tiles over ceiling tiles with reepers 2" x 1" may be allowed at Rs.27-14-0 but not at Rs.28-1-5 as claimed by the Corresponden as the data was based on the P.W.D. schedule of rates.

(5) The piers (A) between the cup boards and door in the History Reading Room should be built in cement mortar above the still level of cup board to the head of the door way and cup board.

With the foregoing remarks the estimate is now reduced from Rs.35000 to Rs.32800,and may be recommended for sanction.

(True copy)

For Director of Public Instruction

14773 / 76 / 10.6

Government of Madras.

Received 1928. Registered 1928

Abstract.

Grant - Building - Construction of an additional block for the St. Agnes High School, Mangalore - (Included in the) List of approved works - ~~Included~~ -

Law (Education) Department.

G. O. No. 1191 & 10.6.29

Read the following :-

Letter From the D.P.I R.C. No. 459.E/26 dated 25/5/1929.

O R D E R :-

The Government sanction the inclusion, in the list of approved works maintained in pursuance of G.O ~~No.572 Law (Education), dated~~ ~~No. 746 Law (Education), dated~~ 10th May 1922 ~~17th June 1922~~ of the construction of an additional block of buildings for the St. Agnes High School, Mangalore, at an estimated cost of Rs. 32,800/- While this approval does not convey any guarantee of grant, it will render the work eligible for a grant (of one-half) ~~not exceeding~~ (not exceeding Rs 16,400/-) under the provisions of the Grant - in - Aid - Code ~~Code of Regulations for European Schools~~ if and when funds become available, provided that all the conditions prescribed in the Code are duly complied with.

DS 16/29. SO 7.6.29

5 Jun 616

Mr. 1 7/6

To the Director of Public Instruction

(with reference to his letter ~~No.~~ R.C. No. 459 E/26 dated 25/5/29. (with enclosures retd)

To the Accountant-General.

Dpd. by Van (1) Peon Messenger (2)

Initials 12/6

8 JUN 1929 DEPARTMENT

GOVERNMENT OF MADRAS 10 JUN 1929 LAW DEPARTMENT